

Excellent Integrated System Limited

Stocking Distributor

Click to view price, real time Inventory, Delivery & Lifecycle Information:

[Molex Connector Corporation](#)
[1301530170](#)

For any questions, you can email us directly:

sales@integrated-circuit.com

This document was generated on 07/06/2016

PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION

Part Number: [1301530170](#)
Status: **Active**
Overview: [Ground Fault Circuit Interrupter \(GFCI\) Products](#)
Description: Safeway® In-Line Commercial GFCI, Permanent Mount, Single Phase, Manual Reset, NEMA L5-30, 30A, 120V, 1.83m (6.0') Cord Length

Documents:

[RoHS Certificate of Compliance \(PDF\)](#)
[Product Literature \(PDF\)](#)

[Product Literature \(PDF\)](#)

Agency Certification

CSA LR6837
UL E66308

General

Product Family Power Distribution
Series 130153
Enclosure Rating NEMA 4
GFCI Reset Manual
Mounting Style Portable
Open Neutral Relay Yes
Overview [Ground Fault Circuit Interrupter \(GFCI\) Products](#)
Product Literature Order No 987650-7737, 987651-0452
Product Name Safeway®
Receptacle Type N/A
Type GFCI Commercial Duty, Single Phase
UPC 78678835074
Woodhead Yes

Physical

Cord Diameter 13.00mm (.512")
Cord Grip Body Size Internal Double C-Clamp
Cord Length 1.83m (6.0')
Feed-Thru Yes
Flip Lid No
Material - Housing Nylon
Number of Receptacles 1
Packaging Type Bag

Electrical

Cord Type 10/3 SJTW
Current - Maximum per Contact 30.0A
GFCI Yes-In-line
Ground Continuity Monitor No
NEMA Configuration NEMA L5-30
Voltage - Maximum 240V

Material Info

Old Part Number 30051-6



EU ELV

Not Reviewed

EU RoHS

Not Reviewed

REACH SVHC

Not Reviewed

Halogen-Free

Status

Not Reviewed

Need more information on product environmental compliance?

Email productcompliance@molex.com
Please visit the [Contact Us](#) section for any non-product compliance questions.

China ROHS

Not Reviewed

ELV

Not Reviewed

Search Parts in this Series

130153 Series

This document was generated on 07/06/2016

PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION