

Excellent Integrated System Limited

Stocking Distributor

Click to view price, real time Inventory, Delivery & Lifecycle Information:

[Phoenix Contact](#)
[2891259](#)

For any questions, you can email us directly:

sales@integrated-circuit.com



Extract from the online catalog

FL MEM PLUG

Order No.: 2891259



<http://eshop.phoenixcontact.de/phoenix/treeViewClick.do?UID=2891259>

Exchangeable configuration memory of the device settings for simple device exchange and set-up

Commercial data	
GTIN (EAN)	 4 046356 165440
sales group	K000
Pack	1 pcs.
Customs tariff	84717098
Catalog page information	Page 315 (NTK-2010)

Product notes

WEEE/RoHS-compliant since:
12/08/2009



<http://www.download.phoenixcontact.com>
 Please note that the data given here has been taken from the online catalog. For comprehensive information and data, please refer to the user documentation. The General Terms and Conditions of Use apply to Internet downloads.

Product description

Memory plug, configuration memory, replaceable

Technical data

Function

Basic functions	Configuration memory (plug-in)
-----------------	--------------------------------

FL MEM PLUG Order No.: 2891259

<http://eshop.phoenixcontact.de/phoenix/treeViewClick.do?UID=2891259>
General data

Weight	25 g
Width	16 mm
Height	57 mm
Degree of protection	IP20
Ambient temperature (operation)	0 °C ... 55 °C (no condensation)
Ambient temperature (storage/transport)	-20 °C ... 70 °C
Permissible humidity (operation)	10 % ... 95 % (no condensation)
Permissible humidity (storage/transport)	10 % ... 95 % (no condensation)
Noise emission	EN 61000-6-3/-4
Noise immunity	EN 61000-6-2:2005

Conformity with EMC directives

Developed in acc. with standard	IEC 61000-6.2
Test standard	IEC 61000-4-2 (ESD)
Test result	Criterion B
Test standard	IEC 61000-4-3 (immunity to radiated interference)
Test result	Criterion A
Test standard	IEC 61000-4-4 (burst)
Test result	Criterion A
Test standard	IEC 61000-4-5 (surge)
Test result	Criterion A
Test standard	IEC 61000-4-6 (immunity to conducted interference)
Test result	Criterion A
Test standard	IEC 61000-4-8 (immunity to magnetic fields)
Test result	Criterion A
Test standard	EN 55022 (emitted interference)
Test result	Criterion A

FL MEM PLUG Order No.: 2891259

<http://eshop.phoenixcontact.de/phoenix/treeViewClick.do?UID=2891259>

Address

PHOENIX CONTACT Deutschland GmbH
Flachsmarktstr. 8
32825 Blomberg, Germany
Phone +49 5235 3 12000
Fax +49 5235 3 41200
<http://www.phoenixcontact.de>



© 2011 Phoenix Contact
Technical modifications reserved;