

Excellent Integrated System Limited

Stocking Distributor

Click to view price, real time Inventory, Delivery & Lifecycle Information:

Molex Connector Corporation 1301360001

For any questions, you can email us directly: sales@integrated-circuit.com



Distributor of Molex Connector Corporation: Excellent Integrated System Limited

Datasheet of 1301360001 - MULTI-TAP W 50FT 12-3-SO

Contact us: sales@integrated-circuit.com Website: www.integrated-circuit.com



This document was generated on 07/06/2016

PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION

 Part Number:
 1301360001

 Status:
 Active

 Overview:
 Outlet Boxes

Description: Super-Safeway® Multi-Tap (3) NEMA L5-15 Outlet Box with Buss Bars, 15.24m (50.0')

Cord Length, 12/3 SOOW Cord, NEMA L5-15 Plug)

Documents:

RoHS Certificate of Compliance (PDF) Product Literature (PDF)

Agency Certification

CŠA LR6837 UL E38085

General

Product Family Power Distribution

Series 130136 **Enclosure Rating** N/A **GFCI** Reset N/A Mounting Style Portable Open Neutral Relay N/A Overview **Outlet Boxes** Product Literature Order No 987650-7737 **Product Name** Super-Safeway™

Receptacle Type Triple

Type Multi-Tap and Strip Cordset

UPC 78678808368

Woodhead Yes

Physical

Cord Diameter N/A

Cord Grip Body Size Double C-Clamp
Cord Length 15.24m (50.0')
Feed-Thru No

Flip Lid No
Material - Housing Rubber
Number of Receptacles 3
Packaging Type Carton

Electrical

Cord Type 12/2 SOOW
Current - Maximum per Contact 15.0A
GFCI No
Ground Continuity Monitor No
NEMA Configuration NEMA L5-15

Voltage - Maximum 120V

oltage - Maximum 120V

Material Info

Old Part Number 32547B123



China RoHS

EU ELV Not Reviewed

EU RoHS Not Reviewed REACH SVHC

Not Reviewed
Halogen-Free
Status

Not Reviewed

Need more information on product environmental compliance?

Email <u>productcompliance@molex.com</u>
Please visit the <u>Contact Us</u> section for any non-product compliance questions.

China ROHS Not Reviewed ELV Not Reviewed

Search Parts in this Series

130136 Series

This document was generated on 07/06/2016

PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION