Excellent Integrated System Limited

Stocking Distributor

Click to view price, real time Inventory, Delivery & Lifecycle Information:

Molex Connector Corporation 1301370116

For any questions, you can email us directly: sales@integrated-circuit.com



Distributor of Molex Connector Corporation: Excellent Integrated System Limited

Datasheet of 1301370116 - DUP 15A/125V FEED-THRU PORT

Contact us: sales@integrated-circuit.com Website: www.integrated-circuit.com



This document was generated on 07/06/2016

PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION

Part Number: 1301370116 Status: Active

Watertite® Wet-Location Wiring Solutions Overview:

Super-Safeway® Multiple Outlet Box, Standard Depth, 2-Sided, Feed-Thru F2 (1/2"), **Description:**

NEMA 5-15 Duplex Receptacles, Cover Plates

Documents:

RoHS Certificate of Compliance (PDF) Product Literature (PDF)

Agency Certification

LR6837 CSA UL E46237

General

Power Distribution **Product Family**

Series 130137 **Enclosure Rating** N/A **GFCI** Reset N/A Mounting Style Portable Open Neutral Relay N/A

Overview Watertite® Wet-Location Wiring Solutions

Product Literature Order No 987650-7737 **Product Name** Super-Safeway™ Receptacle Type Duplex Multiple Outlet Box Type UPC 78678874160

Woodhead

Physical

Cord Diameter 7.92-15.88mm (.312-.625")

Cord Grip Body Size F2 1/2" Cord Length N/A Feed-Thru Yes Flip Lid No Material - Housing Rubber Number of Receptacles Packaging Type Carton

Electrical

Cord Type N/A Current - Maximum per Contact 15.0A No **Ground Continuity Monitor** Nο NEMA 5-15 **NEMA Configuration** 125V

Voltage - Maximum

Material Info

3000F-1 Old Part Number



China RoHS

EU ELV Not Reviewed

EU RoHS

Not Reviewed REACH SVHC

Not Reviewed Halogen-Free <u>Status</u>

Not Reviewed

Need more information on product environmental compliance?

Email productcompliance@molex.com Please visit the Contact Us section for any non-product compliance questions.

China ROHS Not Reviewed ELV Not Reviewed

Search Parts in this Series

130137 Series

This document was generated on 07/06/2016

PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION