

## Excellent Integrated System Limited

Stocking Distributor

Click to view price, real time Inventory, Delivery & Lifecycle Information:

[Molex Connector Corporation](#)  
[1301370241](#)

For any questions, you can email us directly:

[sales@integrated-circuit.com](mailto:sales@integrated-circuit.com)

This document was generated on 07/06/2016

**PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION**

**Part Number:** [1301370241](#)  
**Status:** **Active**  
**Overview:** [Watertite® Wet-Location Wiring Solutions](#)  
**Description:** Watertite® GFCI Coverplate Module for FS/FD Boxes, Clear Silicone, 20A/125V

**Documents:**

[Drawing \(PDF\)](#) [RoHS Certificate of Compliance \(PDF\)](#)

**General**

Product Family	Power Distribution
Series	130137
Enclosure Rating	NEMA 4
GFCI Reset	Manual
Mounting Style	Permanent
Open Neutral Relay	N/A
Overview	<a href="#">Watertite® Wet-Location Wiring Solutions</a>
Product Name	Watertite®
Receptacle Type	N/A
Type	Multiple Outlet Box
UPC	78678809566
Woodhead	Yes

**Physical**

Cord Diameter	N/A
Cord Grip Body Size	N/A
Cord Length	N/A
Feed-Thru	No
Flip Lid	No
Material - Housing	Silicone
Number of Receptacles	0
Packaging Type	Carton

**Electrical**

Cord Type	N/A
Current - Maximum per Contact	20.0A
GFCI	Yes
Ground Continuity Monitor	No
NEMA Configuration	N/A
Voltage - Maximum	125V

**Material Info**

Old Part Number	3362GF
-----------------	--------

**Reference - Drawing Numbers**

Sales Drawing	SD-130137-002
---------------	---------------



**EU ELV**

**Not Reviewed**

**EU RoHS**

**Not Reviewed**

**REACH SVHC**

Not Reviewed

**Halogen-Free**

**Status**

**Not Reviewed**

**Need more information on product environmental compliance?**

Email [productcompliance@molex.com](mailto:productcompliance@molex.com)  
 Please visit the [Contact Us](#) section for any non-product compliance questions.

China ROHS

Not Reviewed

ELV

Not Reviewed

**Search Parts in this Series**

130137 Series

This document was generated on 07/06/2016

**PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION**