

# **Excellent Integrated System Limited**

Stocking Distributor

Click to view price, real time Inventory, Delivery & Lifecycle Information:

Triad Magnetics TCT50-04E07K

For any questions, you can email us directly: sales@integrated-circuit.com



# **Distributor of Triad Magnetics: Excellent Integrated System Limited**

Datasheet of TCT50-04E07K - XFRMR LAMINATED 50VA CHAS MOUNT

Contact us: sales@integrated-circuit.com Website: www.integrated-circuit.com



# Control Transformer Class 2

# TCT50-04E07K

## **Description:**

Triad control transformers come with tamper resistant shrouds for safety and a steel bracket welded to the bottom of the transformer for ease of mounting. These transformers are design and have the safety agency recognition for application where a Class 2 transformer is necessary. Some of the applications would include, but not limited to HVAC, Control boards, Lighting, etc.

# Electrical Specifications (@25C):

- 1. Maximum Power: 50VA
- 2. Input (BLK-RED): 240V, 50/60 Hz, (Fuse: 0.300A Max)
- 3. Output (BLU-BLU):12V @ 4.17Amps
- 4. Voltage Regulation: 15% TYP @ full load to no load
- 5. Temperature Rise: <40°C TYP
- 6. Hipot: 1500VAC Input to Output, Input & Output to Core
- 7. Recommended Fusing: UL Listed, 3AG time-delay type.

#### Construction:

Three flange bobbin construction with primaries and secondaries wound side by side for low capacitive coupling. Unit weight is 2.0lbs.

## **Agency File:**

UL: File E65390, UL 5085-3 (1585), Class 2 Transformer


cUL: File E65390, UL 5085-3 (1585) For Canadian Use (CSA 22.2, No.66.3-06)



#### Connections:

Input: 12±1" insulated leads, stripped and tinned 0.20±0.08", 18AWG stranded Output: 12±1" insulated leads, stripped and tinned 0.20±0.08", 18AWG stranded

### **Schematic:**





**RoHS Compliance:** As of manufacturing date February 2005, all standard products meet the requirements of 2011/65/EU, known as the RoHS initiative.


As of April 7, 2008, UL standards 506 and 1585 will be migrated to UL 5085-2 and 5085-3, respectively.

\* Upon printing, this document is considered "uncontrolled". Please contact Triad Magnetics' website for the most current version.









Web: www.TriadMagnetics.com Phone 951-277-0757 Fax 951-277-2757

460 Harley Knox Blvd. Perris, California 92571

Publish Date: December 4, 2013